



No. CURAJ/R/F.123/2020/1546

16 SEP 2020

Corrigendum

for

Tender for Supply, Installation, Testing & Commissioning of Air Ducting Cum Air Conditioners (Ductable type) and False Ceiling at Auditorium, Academic Building (4A5) at Central University of Rajasthan

NIT No. CURAJ/R/F.123/2020/1543 dated 15.09.2020
NIT Issue date: 15.09.2020
Last date of Submission 06.10.2020 upto 02.00 PM

1. Financial Bid - Item No. A.1 'Supply of Ductable AC'

For - Supply of 11.0 TR capacity Ductable Air conditioning units with inverter type Scroll Compressor with R 410A Refrigerant, vibration isolators, with suitable foundation etc. complete as required. The unit shall deliver the rated capacity at AHRI Conditions and work even at 50°C ambient temperature without tripping. The unit shall be suitable to work on 400V +/- 10%, 3 Phase, 50Hz AC power supply. The unit shall be filled with first charge of the refrigerant and ready for use as required. The COP at AHRI conditions shall not be less than 3.1 and IEER not less than 6.5. Each unit shall comprise of separate Indoor and outdoor unit.

Read as - Supply of 11.0 TR capacity Ductable Air conditioning units with inverter type Scroll Compressor with R 410A Refrigerant, vibration isolators, with suitable foundation etc. complete as required. The unit shall deliver the rated capacity at AHRI Conditions and work even at 50°C ambient temperature without tripping. The unit shall be suitable to work on 400V +/- 10%, 3 Phase, 50Hz AC power supply. The unit shall be filled with first charge of the refrigerant and ready for use as required. The COP at AHRI conditions shall not be less than 3.1 and IEER not less than 6.5. Each unit shall comprise of separate Indoor and outdoor unit. (Make- Daikin/Hitachi/O General/Mitsubhishi).


Registrar 16/9/2020

Central University of Rajasthan